

#11

San Angelo-Tom Green County Health Department

PUBLIC HEALTH BUILDING - 2 CITY HALL PLAZA

P.O. BOX 1751

SAN ANGELO, TEXAS 76902



S. Michael Loving
Director
915/657-4214

SK Engineering
1122 South Bryant
San Angelo, TX 76903

January 20, 2009

Re: Replat of Tract 14 of First Replat in Tract 9, Pecan Creek Subdivision

Dear Mr. Hooker:

We have received and reviewed the plat and planning materials for the above subdivision. This plat consists of 22.336 acres being split into seven tracts. A portion of tract 21 is in the 100 year floodplain and floodway. Any new development on this lot may be subject to the requirements of the Tom Green County Flood Damage Prevention Ordinance. The proposed lot sizes are sufficient for onsite sewage systems. The planning material you provided indicated the soils are not suitable for standard septic systems and therefore each site will have to be evaluated on a case by case basis to determine the type of OSSF to be considered.

All wells must be 100 feet from existing or new septic systems.

All OSSFs in the subdivision must be constructed in compliance with the existing rules and regulations.

If these conditions are met, this department has no objections to the approval of the subdivision.

If you have any question's, please call our office at 657-4493.

Sincerely,

A handwritten signature in cursive script that reads "Karel Zaleski".

Karel Zaleski
Tom Green County Designated Representative

Water
at Your
Service



CONCHO RURAL WATER CORP.
8174 HWY. 87 N., SAN ANGELO, TEXAS 76901
OFFICE: (325) 658-2961

FAX: (325) 658-2962

HOME: (325) 465-4692

March 24, 2008

SKG Engineering
San Angelo, Tex.

Re: Proposed Subdivision Reece Rd.

Dear Herb:

Concho Rural Water Corp. has been contacted By Mr. Bruce Hitt regarding possible water service off of Reece Rd., in Pecan Creek for 20 lots.

Concho Rural Water has the ability to service the above property as long as the Developer follows all guidelines of installation set forth by The TCEQ and TOM GREEN COUNTY rules and regulations.

If You have any Questions Please call me at (325) 658-2961.

Respectfully yours,

B. F. Wiese
President
CRWC

