

**Request for Proposal – MEP**

October 20, 2010

TGC Juvenile Justice Center Smoke Purge, San Angelo, Texas Page 1 of 1

The following Request for Proposal is issued to request pricing to reroute plumbing piping to allow the installation of the proposed exhaust ducts above the sleeping rooms.

- Item #1: Reroute hot and cold water piping above each sleeping room to allow the proposed exhaust ducts to be installed.
- Item #2: Install a #1 feeder tap in the Automatic Transfer Switch to serve the 125 amp main breaker in a NEMA-1 enclosure for Panel "PO" in lieu of replacing the current breaker in Panel "PM". All other work involving Panel "PO" to remain as originally designed.

Please contact me at 325-659-2235 for any questions. My fax number is 325-486-9100.



Paul R. Wilkerson, PE
State of Texas #50732
Firm #F-6257

PowerSystems, Incorporated

P. O. Box 2863 • San Angelo, Texas 76902 • Phone: (325) 659-2235 • Fax: (325) 486-9100



Rafter C Construction
PO Box 2450
San Angelo, Tx 76904
Business: 325-651-8000
Fax: 325-651-8765

Proposal

Date Estimate #

10/22/2010 458

**POWER SYSTEM'S
SAN ANGELO, TX
325-659-2235**

Project/Job Name	Attention:	Rep
TGC JUSTICE CENTER	PAUL WILKERSON	BJ
Description	Cost	
ITEM # 1: RE-ROUTE WATERLINE IN UNITS. FOUR HUNDRED NINETY DOLLARS. (490.00) PER UNIT.	6,370. ⁰⁰	
ITEM # 2: AUTOMATIC TRANSFER SWITCH. \$751.35.	751.35	
	<hr/>	
	\$ 7,121.35	
	1,424.27	
	<hr/>	
IF YOU HAVE ANY QUESTIONS PLEASE CONTACT BRUCE JOHNSON AT 325-656-7097.	\$ 8,545.62	
	191,649. ⁴⁰	
Signature Required for Proposal Approval:	SALES TAX (8.25%)	\$0.00
	TOTAL	\$0.00